

Municipal Pool Facility Hazard Identification Inspection				
Agency:			Inspection Date:	
Name of Inspector:			Title:	
Location Inspected:				
#	Needs Work	OK	N/A	Condition Surveyed
Signage				
1				Load rating for pool posted?
2				All pool rules and restrictions are posted? i.e. no alcohol
3				Is the UV burn index forecast posted daily?
Life Guard Stand				
4				One elevated lifeguard chair is required for each 3,400 ft ² of pool surface
5				A complete spine board with all necessary ties?
6				A unit of lifesaving equipment provided for each 2,000 ft ² of water surface area
7				A rescue tube or rescue buoy at each pool lifeguard station?
8				Suction break E-Switch installed and labeled?
9				All lifeguards have a loud whistle to alert bathers?
10				Lifeguards wear hats, sunglasses and sunscreen? Shade provided?
Wading Pools				
11				Separate filtration system and turnover rate?
12				Physical barrier separating it from other pools?
Diving Boards/ Sliding Boards				
13				Instruction signs and rules posted near the device?
14				Boards have slip-resistant tread surfaces? Slides have running water?
15				Steps & ladders lead to diving boards with handrails to water edge?
Pool Depth Markings				
16				Depth markings are displayed at pool edge & top surface every 25 feet?
17				Depth markings placed at Max & Min points
18				Markings must be minimum 4 inches high in a contrasting color?
Written Plans to Guide Lifeguard Actions				
19				Copy of NJAC 8:26 available to Pool management?
20				A written aquatics supervision plan is available to all lifeguards?
21				A written Emergency Plan is available to all lifeguards?
22				Facility has a written lightning response plan
Chlorine/ Disinfection Treatment Areas				
23				Identification signs posted?
24				Pool makeup water protected by a backflow prevention device?
25				Automatic disinfectant leak detector & alarm installed?
26				Safety Shower /eye wash within 25 feet?
27				Is the Bonding & Grounding certificate posted as required by NJ Law S213?
28				Is pool provided with an automatic means of adding a disinfectant?
Locker Rooms				
29				Slip resistant floors throughout?
30				Electrical fixtures rated for wet areas? All receptacles GFCI protected?

**Write line #'s & comments on back for all "Needs Work" listings, and notify management to initiate required corrective action.
This document does not and is not intended to address every loss potential. There may be other conditions that may contain a potential for liability.*

31				Natural or mechanical ventilation provides minimum of 2 air changes/hour?
Exterior Post lamps				
32				Inspect exterior pole lamp posts for cracks in welds