

Public Pool Facility Hazard Identification Inspection				
Agency:			Pool Name:	
Name of Inspector:			Inspection Date:	
#	Needs Work	OK	N/A	Condition Surveyed
<b>Signage</b>				
1				Load rating, rules and restrictions for pool are posted?
2				Is the UV burn index forecast posted daily?
<b>Main Pool</b>				
3				One elevated lifeguard chair is required for each 3,400 ft <sup>2</sup> of pool surface
4				A complete spine board with all necessary ties?
5				A unit of lifesaving equipment provided for each 2,000 ft <sup>2</sup> of water surface area?
6				A rescue tube or rescue buoy at each pool lifeguard station?
7				Sufficient number of USCG-approved personal flotation devices are available?
8				Suction break E-Switch installed and labeled?
9				All lifeguards have a loud whistle to alert bathers?
10				Lifeguards wear hats, sunglasses and sunscreen? Shade provided?
11				4-inch high depth markings are displayed on pool edge & top surface at maximum & minimum points, and every 25 feet?
<b>Wading Pools</b>				
12				Separate filtration system and turnover rate?
13				Physical barrier separating it from other pools?
<b>Diving Boards/ Sliding Boards</b>				
14				Instruction signs and rules posted near the device?
15				Boards have slip-resistant tread surfaces? Slides have running water?
16				Steps & ladders lead to diving boards with handrails to water edge?
<b>Written Plans to Guide Lifeguard Actions</b>				
17				Copy of NJAC 8:26 available to Pool management?
18				A written aquatics supervision plan is available to all lifeguards?
19				A written Emergency Plan is available to all lifeguards?
20				Facility has a written lightning response plan
<b>Chlorine/ Disinfection Treatment Areas</b>				
21				Identification signs posted?
22				Pool makeup water protected by a backflow prevention device?
23				Automatic disinfectant leak detector & alarm installed?
24				Safety shower /eye wash within 25 feet?
25				Is the bonding & grounding certificate posted as required by NJ Law S-213?
26				Is pool provided with an automatic means of adding a disinfectant?
<b>Locker Rooms</b>				
27				Slip resistant floors throughout?
28				Electrical fixtures rated for wet areas? All receptacles are GFCI protected?
29				Natural or mechanical ventilation provides minimum of 2 air changes/hour?
<b>Exterior Post lamps</b>				
30				Inspect exterior pole lamp posts inspected for cracks in welds

*\*Write line #'s & comments on back for all "Needs Work" listings, and notify management to initiate required corrective action.  
This document does not and is not intended to address every loss potential. There may be other conditions that may contain a potential for liability.*