

Insert EMS agency name Facilities Hazard Identification Inspection				
Inspection Date:			Inspector Name:	
Location Inspected:				
#	Needs Work	N/A	OK	Condition Surveyed: Conditions found to need work should be described on page 2
Exterior Grounds, Walkways and Parking Areas				
				Exterior lighting of grounds, walkways, & parking areas adequate and operational
				Parking lots and driveways free of significant cracks and water accumulation
				Sidewalks, stairs & ramps are free of significant trip or slip hazards
				Landscaping and vegetation do not present a safety or security hazard. (overgrown)
				Yard & recreational areas are clean and organized.
				Outside sheds & storage areas are organized and secured against falling.
				Roofs, gutters, and downspouts are clean and control run-off properly
				Areas are free of signs of rodents, insects, or feral animals.
				Insert additional conditions to be inspected
Life Safety				
				Intrusion alarm is operational and free of trouble or active alarms
				Closed-circuit TV cameras are operational, properly aimed and focused
				Fire sprinkler system is operational, controls valve are accessible, locked & alarmed
				Fire detection system operational and free of trouble or active alarms
				Fire extinguishers are accessible and in good condition – SIGN REAR OF TAGS
				Emergency and Exit lights are lit and worked when the test button/switch is used
				Panic hardware on exit doors worked easily. Doors latched when closing
				Emergency eyewashes and showers are clean, accessible, and flushed monthly
				Insert additional conditions to be inspected
Mechanical Rooms & Areas				
				Outlets and junction boxes are covered. Electrical cords are in good condition.
				36-inch clearance in front of electrical panels and other controls.
				The mechanical Room is free of storage, and access is available to equipment controls.
				Flammable & combustible liquids stored in flammable cabinets. Only 1 day supply out
				Storage and dispensing areas of hazardous substances are clean, organized & labeled
				Tools and cleaning supplies are properly stored
				Laundry room/area is clean and organized. Dryer lint accumulation is minimal.
				Insert additional conditions to be inspected
Ambulance and Vehicle Bays				
				Door closer controls and sensors are operating properly.
				Bay floor surfaces are clean and free of slip and trip hazards. Storage is not in aisles.
				Landline cords and air hoses do not pose a tripping hazard.
				Compressed gas cylinders are secured by chains or brackets. None are unsecured.
				Oxygen cascade system cylinders are secured. Hoses and fittings are in good condition.

